



NOTES:

1. CATCH BASIN TO BE USED ONLY IN AREAS WHERE CURB INLET CONFLICTS WITH UNDERGROUND UTILITIES AND WITH THE APPROVAL OF THE CITY'S AUTHORIZED REPRESENTATIVE.
2. CONCRETE SHALL ATTAIN A MIN. COMPRESSIVE STRENGTH OF 3000 PSI. IN 28 DAYS.
3. BATTER OF 1/4" TO 1" TO FACILITATE FORM REMOVAL WILL BE ALLOWED.
4. BOTTOM OF WEEP HOLE SHALL BE LOCATED AT BOTTOM OF ROADWAY BASE ROCK.
5. SEE DETAIL S-2096 FOR REBAR SPACING AND HOOK BAR DETAIL.

Detail Drawing may not be altered or changed in any manner except by the Public Works Director. It is the responsibility of the user to acquire the most current version.

CITY OF MOLALLA
DEPARTMENT OF PUBLIC WORKS



CATCH BASIN
Type G-2

DRAWN BY	PDG	04/2016
CHECKED BY	JC	04/2016

S-2095