



Public Works Department

117 N Molalla Avenue

PO Box 248

Molalla, Oregon 97038

Phone: (503) 829-6855

Fax: (503) 829-3676

Website Posting

April 07, 2022

Based on information at the time of required posting, the City did not violate the NPDES Permit conditions (as modified by the March 2021 MAO) for the month of ~~February 2022.~~

March 2022

Effluent did exceed unmodified NPDES Permit limit as follows:

Monthly Average BOD5 loading (limit 160 lbs): 202lbs

Daily Max BOD5 loading (limit 320 lbs): 322 lbs (dates 3/24)

Weekly Average BOD5 loading (limit 240 lbs): 261 lbs (dates 3/23-3/31)

Weekly Average BOD5 concentration (limit 15 mg/L): 16 mg/L (dates 3/23-3/31)