



Public Works Department

117 N Molalla Avenue

PO Box 248

Molalla, Oregon 97038

Phone: (503) 829-6855

Fax: (503) 829-3676

Website Posting

June 3, 2022 (Updated 6/8/22)

Based on information at the time of required posting, the City violated the NPDES Permit conditions (as modified by the March 2021 MAO) for the month of May 2022 as follows:

Monthly average is BOD5 13 mg/L (NPDES limit 10mg/L; MAO limit 25mg/L);

Monthly average loading 241 lbs/day (NPDES limit 160 lbs; MAO 400 limit lbs),

Weekly average loading 260 lbs/day for week of 5/22 - 5/28 (NPDES limit 240 lb; MAO limit 600)

Weekly average loading 251 lbs/day for week of 5/29 - 5/31 (NPDES limit 240 lb; MAO limit 600)

Out of Season Discharge 5/17 – 5/31,

7 day average Temperature greater than 18 degrees Celsius 5/23 – 5/31 (NPDES limit 18 degrees C).