



Public Works Department

117 N Molalla Avenue

PO Box 248

Molalla, Oregon 97038

Phone: (503) 829-6855

Fax: (503) 829-3676

Website Posting

May 6, 2022 (UPDATED 5/16/22)

Based on information at the time of required posting, the City violated the NPDES Permit conditions (as modified by the March 2021 MAO) for the month of April 2022 as follows:

Weekly Average BOD5 loading (NPDES limit 240 lbs, MAO limit 600): 609 lbs (dates 4/22-4/29)

and the Unmodified NPDES Permit as follows:

Monthly Average BOD5 lbs loading (NPDES limit 160 lbs): 296 lbs (4/1-4/29)

Daily Maximum BOD5 lbs loading (NPDES limit 320 lbs): 615 lbs (4/26); 602 lbs (4/27)

Monthly Average BOD5 mg/L (NPDES limit 10mg/L): 15mg/L (4/1-4/29)

Weekly Average BOD5 mg/L (NPDES limit 15 mg/L): 29 mg/L (4/22-4/29)