



Community Development Department
315 Kennel Avenue, PO Box 248, Molalla, Oregon 97038
Phone: (503) 759-0205

Website Posting

Dec 1, 2023

Based on information at the time of required posting, the City experienced one violation of the NPDES Permit conditions (as modified by the March 2021 MAO) for the month of November 2023.

1. The Monthly Average Ammonia concentration was 20.1 mg/L (NPDES Permit Limit 16.7 mg/L)

October DEQ correspondence is Attached to this Posting.

RE: Monitoring Request: Molalla STP PN 101514



Seth Kelly
To: 'CANNON George * DEQ'



Wed 11/29/2023 11:17 AM

 This message is part of a tracked conversation. [Click here to find all related messages or to open the original flagged message.](#)

Hi George,

Thank you for chatting with me shortly this morning. I will call you tomorrow around 9am, hopefully they get you power back soon. I am hoping to gain a clearer picture of what is desired for from the additional testing you requested. I additionally want to confirm some expectations of the testing requested. I know that the City of Molalla has conducted its Tier I / II Testing and has been conducting the Copper Biotic Ligand testing and looking to be completed with that in April of 2024. In looking over the analysis requests and data acquired from these tests. I am curious if there is a reason, we would not want use any of this data for the formation of our new permit. My hope during our discussion in the morning to find a better understanding of what this testing will facilitate as well as possibly eliminate duplication of acquiring data necessary for the build of our new NPDES Permit.

Respectfully,

Seth Kelly, Molalla WWTP Manager

12424 S Toliver Rd. | Molalla, OR 97038

Phone – 503.302.3600

Email – skelly@cityofmolalla.com

Website – <http://www.cityofmolalla.com>

From: CANNON George * DEQ <George.CANNON@deq.oregon.gov>

Sent: Tuesday, November 28, 2023 2:32 PM

To: Mac Corthell <mcorthell@cityofmolalla.com>

Cc: Seth Kelly <skelly@cityofmolalla.com>; YELTON-BRAM Tiffany * DEQ <Tiffany.YELTON-BRAM@deq.oregon.gov>; BAILEY Randall * DEQ <Randall.BAILEY@deq.oregon.gov>; NAVARRO Jeffrey * DEQ <Jeffrey.NAVARRO@deq.oregon.gov>; BODNAR Rebecca * DEQ <Rebecca.Bodnar@deq.oregon.gov>

Subject: Monitoring Request: Molalla STP PN 101514

Hello Macahan,

I hope this email finds you well. After reviewing our records and the data you submitted to us we have determined that supplemental information will be necessary for the City of Molalla (101514) NPDES renewal. Please find attached a monitoring request letter. This is to ensure that we have the necessary information to evaluate your facility's site specific conditions.

Please review the letter, and contact me with any questions or concerns. Requests for extensions or modifications must be made within two weeks of the letter date (11/28/2023) If you are looking for a laboratory that can perform the requested analyses, The NELAC Institute's laboratory search tool may be of assistance: <https://lams.nelac-institute.org/Search>. DEQ also has a template QAPP/SAP document in case you need to develop one. It can be found here: <https://www.oregon.gov/deq/wq/wqpermits/Pages/Forms.aspx>. The link to the template is near the bottom of the page under "Guidance documents"; it is the "Template for Quality Assurance Project Plan and Sample Analysis Plan". Also at this link is guidance

Regards,

George

From: CANNON George * DEQ <George.CANNON@deq.oregon.gov>

Sent: Tuesday, November 28, 2023 2:32 PM

To: Mac Corthell <mcorthell@cityofmolalla.com>

Cc: Seth Kelly <skelly@cityofmolalla.com>; YELTON-BRAM Tiffany * DEQ <Tiffany.YELTON-BRAM@deq.oregon.gov>; BAILEY Randall * DEQ <Randall.BAILEY@deq.oregon.gov>; NAVARRO Jeffrey * DEQ <Jeffrey.NAVARRO@deq.oregon.gov>; BODNAR Rebecca * DEQ <Rebecca.Bodnar@deq.oregon.gov>

Subject: Monitoring Request: Molalla STP PN 101514

Hello Macahan,

I hope this email finds you well. After reviewing our records and the data you submitted to us we have determined that supplemental information will be necessary for the City of Molalla (101514) NPDES renewal. Please find attached a monitoring request letter. This is to ensure that we have the necessary information to evaluate your facility's site specific conditions.

Please review the letter, and contact me with any questions or concerns. Requests for extensions or modifications must be made within two weeks of the letter date (11/28/2023) If you are looking for a laboratory that can perform the requested analyses, The NELAC Institute's laboratory search tool may be of assistance: <https://lams.nelac-institute.org/Search>. DEQ also has a template QAPP/SAP document in case you need to develop one. It can be found here: <https://www.oregon.gov/deq/wg/wqpermits/Pages/Forms.aspx>. The link to the template is near the bottom of the page under "Guidance documents"; it is the "Template for Quality Assurance Project Plan and Sample Analysis Plan". Also at this link is guidance

Regards,

George

George Cannon, EIT
Permit Developer
Oregon Department of Environmental Quality
Water Quality Permitting and Program Development
700 NE Multnomah St., Suite #600 Portland, OR 97232
Phone: 503.734.9843
Email: George.CANNON@deq.oregon.gov

PUBLIC RECORDS LAW DISCLOSURE: This is a public document. This email may be subject to the state retention schedule and made available to the public.