



Community Development Department
315 Kennel Avenue, PO Box 248, Molalla, Oregon 97038
Phone: (503) 759-0205

Website Posting

May 2, 2023

Based on information at the time of required posting, the City experienced no violations of the NPDES Permit conditions (as modified by the March 2021 MAO) for the month of April 2023.

Effluent did exceed unmodified NPDES limits as follow:

Monthly Average BOD5 concentration (limit 10 mg/L): 12 mg/L

Monthly Average BOD5 Loading (limit 160 lbs): 283 lbs

Weekly Average BOD5 concentration (limit 15 mg/L): 17 mg/L on 4/23-4/29

Weekly Average BOD5 Loading (limit 240 lbs): 254lbs on 4/9-4/15, 290lbs on 4/16-4/22, 381lbs on 4/23-4/29

Daily Max BOD5 loading (limit 320lbs): 329lbs on 4/18/23, 370lbs on 4/25/23, and 391lbs on 4/26/23