



Community Development Department
315 Kennel Avenue, PO Box 248, Molalla, Oregon 97038
Phone: (503) 759-0205

Website Posting

April 2, 2024

Based on information at the time of required posting, the City experienced no violation of the NPDES Permit conditions (as modified by the March 2021 MAO) for the month of March 2024.

Effluent did exceed unmodified NPDES limits as follow:

Monthly Average BOD5 Loading (limit 160 lbs): 185 lbs

Monthly Average BOD5 Concentration (limit 10 mg/l): 15 mg/l

Weekly Average BOD5 Loading (limit 240 lbs): 3/10/24 - 3/16/24, 253 lbs

Weekly Average BOD5 Concentration (limit 15 mg/l): 3/10/24 – 3/16/24, 18 mg/l
3/17/24 – 3/23/24, 20 mg/l
3/24/24 – 3/30/24, 16 mg/l

Daily Average BOD5 Loading (limit 320 lbs): 3/12/24, 326 lbs

March DEQ Correspondence attached below:

February Non-Compliance



Seth Kelly

To 'PINNEY Mike * DEQ'



Tue 3/5/2024 3:58 PM

Hi Mike,

As discussed on the phone the City of Molalla STP had a violation for February with 84% removal instead of 85% and a weekly loading average exceedance of 644 lbs (44lbs over the limit). I will fill out the non-compliance form once I have it and forward that on as well. As stated in an earlier email. I believe the violations stem from a dirty sampler suction hose. We have added the cleaning of the sampler to our work order list and all results since cleaning this sampler line have been within our limits. I will also make note on the NetDMR submission.

Respectfully,

Seth Kelly

Molalla Wastewater Treatment Plant Manager

12424 S. Toliver Rd, Molalla, OR, 97317

skelly@cityofmolalla.com

503-302-3600

Feb Non-Compliance



Seth Kelly

To 'PINNEY Mike * DEQ'



Non-Compliance_Feb_24.pdf

1 MB



Wed 3/6/2024 3:38 PM

Hi Mike,

Here is the Non-Compliance for February for the City of Molalla.

Seth Kelly

Molalla Wastewater Treatment Plant Manager

12424 S. Toliver Rd, Molalla, OR, 97317

skelly@cityofmolalla.com

503-302-3600

City of Molalla WTP - Stormwater



KENNEDY Mike * DEQ <Mike.KENNEDY@deq.oregon.gov>

To Mac Corthell

Cc Seth Kelly



Thu 3/14/2024 9:13 AM

Flag for follow up.
You replied to this message on 3/14/2024 3:23 PM.

[Suggested Meetings](#) [Action Items](#)

[+ Get more add-ins](#)

Morning Mac and Seth,

I am with the industrial stormwater program at DEQ. Mark Hynson looped me in on your NPDES renewal, as your facility is changing from a minor to a major facility. I tried calling 503-759-0243, but it went to a general voicemail and I didn't want to leave a message to a general number.

Wastewater treatment works that have a design flow capacity of 1.0 mgd or more or facilities that have a pretreatment program could be eligible for coverage under the 1200-Z industrial stormwater permit separately from the wastewater permit. I'd like to chat with either of you about this and can meet with you at the facility at one of the following times:

Any time between 7-1 on 3/18

1130-230 on 3/21

11-230 on 3/25

Any time between 7-230 on 3/27

Let me know which works best for you and I'll send an invite.

Regards,

Michael Kennedy | DEQ Stormwater

He | Him | His | [Why share pronouns?](#)

503-729-6488 (talk/text)

RE: City of Molalla WTP - Stormwater



Seth Kelly

To 'KENNEDY Mike * DEQ'; Ryan Quigley

Cc Mac Corthell



Thu 3/14/2024 3:24 PM

Hi Michael,

I have added in Ryan with Dyer Partnership (the City's Engineer of record) as well. He and I would be available to meet at our facility on 3/21 @ 12:30. Is this permit for the facility's onsite stormwater collection? All the new constructions impervious surface and stormwater collection will drain back into the Wastewater Treatment Plants lift station and be treated with the Sanitary Sewer waste through the new SBR and following apparatuses. We would be glad to have you out to the facility and meet with you if you see it necessary. Feel free to call my number below if you have any further questions.

Thank you,

Seth Kelly

Molalla Wastewater Treatment Plant Manager

12424 S. Toliver Rd, Molalla, OR, 97317

skelly@cityofmolalla.com

503-302-3600


Molalla Wastewater Treatment Plant 1200-Z Notice



KENNEDY Mike * DEQ <Mike.KENNEDY@deq.oregon.gov>

To: Mac Corthell

Cc: Seth Kelly; HYNSON Mark * DEQ

 Follow up. Start by Monday, April 1, 2024. Due by Monday, April 1, 2024.



Molalla WTP 1200-Z Permit Notice.pdf

207 KB



Reply



Reply All



Forward



Fri 3/22/2024 11:44 AM

Mac,

See the attached letter. Let me know if you have questions.

Regards,

Michael Kennedy | DEQ Stormwater

He | Him | His | [Why share pronouns?](#)

503-729-6488 (talk/text)