



NOTES:

1. EXTEND 2" NUT TO WITHIN 18" OF FINISH GRADE WHEN VALVE NUT IS DEEPER THAN 3 FEET FROM FINISHED GRADE.
2. WHERE DEPTH IS OVER 6 FEET, A SECOND PLATE WILL BE INSTALLED EQUIDISTANT BETWEEN FIRST ROCK GUARD AND 2" VALVE NUT.
3. WATERLINE DEEPER THAN 4 FEET SHALL BE APPROVED BY CITY'S AUTHORIZED REPRESENTATIVE.
4. SEE DETAIL W-3020 WATER VALVE BOX & LID FOR ADDITIONAL STANDARD REQUIREMENTS.

Detail Drawing may not be altered or changed in any manner except by the Public Works Director. It is the responsibility of the user to acquire the most current version.

CITY OF MOLALLA
DEPARTMENT OF PUBLIC WORKS



VALVE OPERATOR EXTENSION

DRAWN BY	PDG	04/2016
CHECKED BY	JC	04/2016

W-3015