



- NOTES:
1. ALL PIPE FITTINGS SHALL BE DUCTILE IRON.
 2. VALVE BOXES SHALL BE PER DETAIL DRAWING W-3020.
 3. VALVE BOXES SHALL BE CONCRETE ENCASED AS SHOWN, IF NOT IN PAVED AREA.
 4. BLOW-OFF SHALL BE BACKFILLED WITH 3/4"-Ø CRUSHED ROCK AND COMPACTED TO 95% OF MAX. DENSITY DETERMINED BY AASHTO T-180.
 5. BACKFILL SHALL BE A MINIMUM WIDTH OF 6" ON ALL SIDES.
 6. PLACE BLOW-OFF STANDPIPE 3 FT. INSIDE R.O.W. LINE AT END OF STREET (2FT. FROM BARRICADE).
 7. BLOW-OFF NOT TO BE LOCATED IN GUTTER OR DITCH.
 8. 6" BLOW-OFF FOR USE ON PIPE SIZES 14" IN DIAMETER OR LARGER.

Detail Drawing may not be altered or changed in any manner except by the Public Works Director. It is the responsibility of the user to acquire the most current version.

**CITY OF MOLALLA
DEPARTMENT OF PUBLIC WORKS**



**STANDARD BLOW-OFF
6 Inch**

DRAWN BY	PDG	05/2016
CHECKED BY	JC	05/2016

W-3055