


NOTES:

1. VALVE BOX TO BE CONCRETE ENCASED AS SHOWN, IF NOT IN PAVED AREA.
2. BLOW-OFF UNIT SHALL BE BACKFILLED WITH 3/4"-0 CRUSHED ROCK AND COMPACTED TO 95% OF MAX. DENSITY DETERMINED BY AASHTO T-180.
3. BLOW-OFF NOT TO BE LOCATED IN GUTTER OR DITCH.
4. 2" BLOW-OFF FOR USE ON PIPE SIZES UP TO 12 INCHES IN DIAMETER INCLUDING TEMPORARY DEAD ENDS OR PLANNED FUTURE EXTENSIONS OF MAIN.
5. FOR PERMANENT DEAD ENDS USE 2" BLOW-OFF ON 8 INCH WATER MAIN.

Detail Drawing may not be altered or changed in any manner except by the Public Works Director. It is the responsibility of the user to acquire the most current version.

**CITY OF MOLALLA
DEPARTMENT OF PUBLIC WORKS**



**2" BLOW-OFF DETAIL
12" & SMALLER WATERLINE**

DRAWN BY	PW	01/2020
CHECKED BY	GF	01/2020

W-3075