

PLANT INFLUENT				PLANT EFFLUENT : REUSE																				REMARKS	
DAY	INF. MGD	EFF. MGD	Molalla River CFS	pH	BOD mg/L	TSS mg/L	Temp	pH	Max Temp	Min DO	NH3	BOD mg/L	BOD % Rem	BOD Disch. lbs	TSS mg/L	TSS % Rem	TSS Disch. Lbs	Chlorine Used lbs	Field Cl2 Residual	Total Colif	Turbidity	MOL 1400-DO	River 1800 Temp	RAIN inch	Day
1	0.703	1.259		7.4			20.1	7.0										73	1.30	<1	0.65	10.3	17.3	0.00	1
2	0.721	0.498		7.6	258	365	20.1	7.2										19	1.80	<1	0.70	10.9	16.1	0.10	2
3	0.788			7.2			20.1															10.3	15.4	0.45	3
4	0.949																							0.28	4
5	0.884																							0.15	5
6	0.837			7.4			21.2															10.8	14.5	0.45	6
7	0.996			7.4	229	194	21.3															10.9	14.1	0.00	7
8	0.836			7.3			19.5															11.2	12.9	0.00	8
9	0.807			7.3	258	261	19.2															11.6	11.7	0.20	9
10	0.794			7.4			19.4															11.8	11.2	0.00	10
11	0.744																							0.00	11
12	0.733																							0.00	12
13	0.756			7.4			19.1															12.0	11.8	0.00	13
14	0.743			7.0		295	19.1															12.1	11.9	0.00	14
15	0.712			7.1			19.1															11.2	11.7	0.00	15
16	0.712			7.2			18.9															11.9	11.2	0.00	16
17				6.8			19.1																		17
18																									18
19																									19
20																									20
21																									21
22																									22
23																									23
24																									24
25																									25
26																									26
27																									27
28																									28
29																									29
30																									30
31																									31
Total	12.715	1.757																92						1.63	TOTAL
MAX	0.996	1.259		7.6	258	365	21.3	7.2										73	1.80					0.45	MAX
MIN	0.703	0.498		6.8	229	194	18.9	7.0										19	1.30					0.00	MIN
AVG	0.795	0.879		7.3	248	279	19.7	7.1										46	1.55	<1	0.7	11.3	13.3	0.10	AVG
PERMIT STAND								6-9													2.2/100ml	2.0 Daily Average			PERMIT STAND

PRINCIPAL OPERATOR NAME: Otis Phillips TREATMENT CERTIFICATION # AND GRADE: 10506 LEVEL 4  
 SIGNATURE: \_\_\_\_\_ COLLECTIONS CERTIFICATION # AND GRADE: 7848 LEVEL 1  
 During this reporting period did all monitoring data & sampling frequencies meet permit requirements & limits (if "no", explain)? YES NO  
 During this reporting period were there unanticipated bypasses or upsets which exceeded any effluent limits (if "yes", explain)? NO YES  
 During this reporting period was there any collections system overflows (if "yes" explain)? NO YES

