

PLANT INFLUENT				PLANT EFFLUENT : REUSE																	MOL 1400-DO			River 1800 Temp	RAIN inch	Day
DAY	INF. MGD	EFF. MGD	Molalla River CFS	pH	BOD mg/L	TSS mg/L	Temp	pH	Max Temp	Min DO	NH3	BOD mg/L	BOD % Rem	BOD Disch. lbs	TSS mg/L	TSS % Rem	TSS Disch. Lbs	Chlorine Used lbs	Field Cl2 Residual	Total Colif	Turbidity					
1	0.703	1.259		7.4			20.1	7.0										73	1.30	<1	0.65	10.3	17.3	0.00		1
2	0.721	0.498		7.6	258	365	20.1	7.2										19	1.80	<1	0.70	10.9	16.1	0.10	Plant Shut Down 0830, Irr.Season Ended.	2
3	0.788			7.2			20.1															10.3	15.4	0.45		3
4	0.949																							0.28		4
5	0.884																							0.15		5
6	0.837			7.4			21.2															10.8	14.5	0.45		6
7	0.996			7.4	229	194	21.3															10.9	14.1	0.00		7
8	0.836			7.3			19.5															11.2	12.9	0.00		8
9	0.807			7.3	258	261	19.2															11.6	11.7	0.20		9
10	0.794			7.4			19.4															11.8	11.2	0.00		10
11	0.744																							0.00		11
12	0.733																							0.00		12
13	0.756			7.4			19.1															12.0	11.8	0.00		13
14	0.743			7.0	284	295	19.1															12.1	11.9	0.00		14
15	0.712			7.1			19.1															11.2	11.7	0.00		15
16	0.712			7.2	296	325	18.9															11.9	11.2	0.00		16
17	0.711			6.8			19.1															12.0	11.6	0.10		17
18	0.737																							0.00		18
19	0.772																							0.00		19
20	1.131			6.9			18.7															11.1	11.8	0.73		20
21	1.003			6.6		157	18.5															11.6	11.9	0.00		21
22	0.873			6.6			18.3															11.9	11.5	0.00		22
23				6.9			18.3																			23
24																										24
25																										25
26																										26
27																										27
28																										28
29																										29
30																										30
31																										31
Total	17.942	1.757																92							2.46	TOTAL
MAX	1.131	1.259		7.6	296	365	21.3	7.2										73	1.80					0.73	MAX	
MIN	0.703	0.498		6.6	229	157	18.3	7.0										19	1.30					0.00	MIN	
AVG	0.816	0.879		7.1	265	266	19.4	7.1										46	1.55	<1	0.7	11.4	12.9	0.11	AVG	
PERMIT STAND								6-9													2.2/100ml	2.0 Daily Average			PERMIT STAND	

PRINCIPAL OPERATOR NAME: Otis Phillips TREATMENT CERTIFICATION # AND GRADE: 10506 LEVEL 4
 SIGNATURE: _____ COLLECTIONS CERTIFICATION # AND GRADE: 7848 LEVEL 1
 During this reporting period did all monitoring data & sampling frequencies meet permit requirements & limits (if "no", explain)? YES NO
 During this reporting period were there unanticipated bypasses or upsets which exceeded any effluent limits (if "yes", explain)? NO YES
 During this reporting period was there any collections system overflows (if "yes" explain)? NO YES

