

DAY	PLANT INFLUENT				PLANT EFFLUENT : REUSE																MOL 1400-DO	River 1800 Temp	RAIN inch	REMARKS	Day	
	INF. MGD	EFF. MGD	Molalla River CFS	pH	BOD mg/L	TSS mg/L	Temp	pH	Max Temp	Min DO	NH3	BOD mg/L	BOD % Rem	BOD Disch. lbs	TSS mg/L	TSS % Rem	TSS Disch. Lbs	Chlorine Used lbs	Field Cl2 Residual	Total Colif						Turbidity
1	0.760																					9.8	18.1	0.00	Plant Off.	1
2	0.742			7.4	323	402	20.1															9.6	19.1	0.00		2
3	0.734			7.3			20.8															9.6	19.2	0.00		3
4	0.722			7.4	255	387	20.7															9.5	19.2	0.00		4
5	0.703			7.3			20.7																	0.00		5
6	0.712																							0.00		6
7	0.761																							0.00		7
8	0.707			7.7			22.2															9.5	19.8	0.00		8
9	0.708			7.6	277	354	20.3															8.5	20.9	0.00		9
10	0.695			7.6			20.7															8.6	19.7	0.00		10
11	0.707			7.5	235	319	20.5															8.7	20.8	0.00		11
12	0.694																					8.9	20.6	0.00		12
13	0.711																							0.00		13
14	0.720	0.461																33						0.00	Start Plant 12:00. Filling FM = .461MG	14
15	0.697	1.350		7.7			20.7	6.8										62	0.70	3.1	1.20	9.0	20.1	0.00	Filling FM = .189MG. Start Irrigation 10:00	15
16	0.701	1.348		7.5	273	232	20.7	7.0										73	0.70	<1	1.00	9.5	19.9	0.00		16
17	0.703	1.316		7.4			20.8	6.9										63	0.90	<1	1.10	9.7	19.8	0.00		17
18	0.696	1.187		7.4	262	351	20.7	6.9										82	0.80	<1	0.80	10.2	16.5	0.00		18
19	0.692	1.233		7.5			20.6	6.9										62	0.90	<1	0.90	10.4	17.9	0.00		19
20	0.703	1.343																83	0.90	<1	0.90			0.03		20
21	0.765	1.323																68	0.80	<1	0.80			0.30		21
22	0.793	1.196		7.5			21.3	6.8										64	0.80	<1	0.90	10.2	16.7	0.00		22
23	0.720	0.997		7.6	290	362	20.8	6.6										67	1.50	<1	0.80	10.5	15.6	0.00		23
24	0.813	1.044		7.2			20.1	6.4										67	2.20	<1	0.90	10.6	16.1	0.50		24
25	0.865	1.006		7.2	204	250	20.0	7.0										67	0.80	<1	0.70	10.5	15.7	0.10		25
26	0.775	0.999		7.1			19.8	6.9										80	1.30	<1	0.75	10.5	15.9	0.00		26
27	0.774	0.969						6.9										73	0.70	<1	0.80			0.00		27
28	0.789	0.954						7.1										66	0.70	<1	0.85			0.00		28
29	0.747	1.103		7.3			19.8											62	1.70	<1	0.80	10.7	17.2	0.00		29
30	0.706	1.254		7.4		390	20.1	7.0										62	1.50	<1	0.65	10.7	17.9	0.00		30
31																										31
Total	22.015	19.083																1134						0.93		TOTAL
MAX	0.865	1.350		7.7	323	402	22.2	7.1										83	2.20					0.50		MAX
MIN	0.692	0.461		7.1	204	232	19.8	6.4										33	0.70					0.00		MIN
AVG	0.734	1.123		7.4	265	339	20.6	6.9										67	1.06	<1	0.9	9.8	18.4	0.03		AVG
PERMIT STAND								6-9													2.2/100ml	2.0 Daily Average				PERMIT STAND

PRINCIPAL OPERATOR NAME: Otis Phillips	TREATMENT CERTIFICATION # AND GRADE: 10506 LEVEL 4	
SIGNATURE: _____	COLLECTIONS CERTIFICATION # AND GRADE: 7848 LEVEL 1	
During this reporting period did all monitoring data & sampling frequencies meet permit requirements & limits (if "no", explain)?	YES	NO
During this reporting period were there unanticipated bypasses or upsets which exceeded any effluent limits (if "yes", explain)?	NO	YES
During this reporting period was there any collections system overflows (if "yes" explain)?	NO	YES

